

Number	88248/01	Replaces	--
Issued	18-06-2015	Scope	2009/142/EC 92/42/EEC
Report number	140101977		
PIN	0063CQ3977	Contract number	E 8090

## EC TYPE EXAMINATION CERTIFICATE

Kiwa hereby declares that the **Low Temperature Central Heating Boilers**, types

**VUW 240/5-3 (H-SEE-EU) atmoTEC pro**  
**VUW 240/5-3 (H-CZ) atmoTEC pro**  
**VUW 240/5-5 (H-CZ) atmoTEC plus**  
**VUW 240/5-3 (H-HU) atmoTEC pro**  
**VUW 240/5-3 (H-PL) atmoTEC pro**

Supplied by

**Vaillant GmbH**  
**Remscheid , Germany**

meet the essential requirements as described in the  
**Directive 2009/142/EC relating to appliances burning gaseous fuels** and the  
**Directive 92/42/EEC on efficiency requirements.**

Country of destination, appliance categories, installation types and available types  
are mentioned in the appendix to this certificate.

Certificate

**Kiwa Nederland B.V.**  
Wilmersdorf 50  
P.O. Box 137  
7300 AC APELDOORN  
The Netherlands

[www.1kiwa.com](http://www.1kiwa.com)

**GASTEC**




*B. Meekma*

Bouke Meekma  
Kiwa

**kiwa**  
Approved

EC Directive



2009/142/EC  
92/42/EEC

**GASTEC**



0063

**0063**  
Page 1 of 1

CERTIFICATE 88248/01

Appendix no.: 1  
Dated: June-2015  
Examination report(s): 140101977

**List of available types,**

Type name	Appliance type	Heat input (kW)
VUW 240/5-3 (H-SEE-EU) atmoTEC pro	B11BS	10.7 - 26.7
VUW 240/5-3 (H-CZ) atmoTEC pro	B11BS	10.7 - 26.7
VUW 240/5-5 (H-CZ) atmoTEC plus	B11BS	10.7 - 26.7
VUW 240/5-3 (H-HU) atmoTEC pro	B11BS	10.7 - 26.7
VUW 240/5-3 (H-PL) atmoTEC pro	B11BS	10.7 - 26.7

Directives

Gas Appliance Directive (2009/142/EC)  
Boiler Efficiency Directive (92/42/EEC)

Standard

EN 15502-2-2: 2014, EN 15502-1:2012

Appliance category

I12H3B/P G20 - 20mbar, G30/G31 - 30 mbar  
I12HS3B/P G20 - 25mbar, G25.1 - 25mbar, G30/G31 - 30mbar  
I12ELwLs3B/P G20 - 20mbar, G27 - 20mbar, G 2.350 - 13mbar, G30/G31 - 37mbar

Countries of destination

Czech Republic (CZ), Slovakia (SK), Hungaria (HU), Polen (PL), Croatia (HR)